#### **DATASHEET - M22-LCH-G**



Indicator light, RMQ-Titan, Extended, conical, without light elements, For filament bulbs, neon bulbs and LEDs up to 2.4 W, with BA 9s lamp socket, green



Part no. M22-LCH-G Catalog No. 216916 Alternate Catalog M22-LCH-GQ

No.

**EL-Nummer** 4355443

(Norway)

### **Delivery program**

| Zonio, program             |   |    |   |
|----------------------------|---|----|---|
| Product range              |   |    | RMQ-Titan   |
| Basic function             |   |    | Indicator lights  |
| Mounting hole diameter     | Ø | mm | 22.5  |
| Single unit/Complete unit  |   |    | Complete unit   |
| Design                     |   |    | Extended, conical   |
| Description                |   |    | without light elements For filament bulbs, neon bulbs and LEDs up to 2.4 W with BA 9s lamp socket |
| Colour                     |   |    |   |
| Lens                       |   |    | green   |
| Lens                       |   |    |   |
| Degree of Protection       |   |    | IP66, IP67, IP69  |
| Connection to SmartWire-DT |   |    | no  |
|                            |   |    |   |

# **Technical data**

#### General

| General                     |                 |  |
|-----------------------------|-----------------|--|
| Standards                   |                 | IEC/EN 60947<br>VDE 0660   |
| Climatic proofing           |                 | Damp heat, constant, to IEC 60068-2-78<br>Damp heat, cyclic, to IEC 60068-2-30 |
| Degree of Protection        |                 | IP66, IP67, IP69   |
| Ambient temperature         |                 |  |
| Open                        | °C              | -25 - +70  |
| Mounting position           |                 | As required  |
| Mechanical shock resistance | g               | 30<br>Shock duration 11 ms<br>Sinusoidal<br>according to IEC 60068-2-27        |
| Terminal capacities         | $mm^2$          |  |
| Solid                       | mm <sup>2</sup> | 0.5 - 1.5  |
| Stranded                    | mm <sup>2</sup> | 0.5 - 1.5  |
| shipping classification     |                 | DNV<br>GL<br>LR  |
|                             |                 | Lloyd's Register  DIV Germanischer Lloyd  TYPE APPROVED                        |

#### Contacts

| Rated impulse withstand voltage       | $U_{\text{imp}}$ | V AC | 4000  |
|---------------------------------------|------------------|------|-------|
| Rated insulation voltage              | $U_{i}$          | V    | 250   |
| Overvoltage category/pollution degree |                  |      | III/3 |

# Design verification as per IEC/EN 61439

| Design verification as per 120/214 01733   |                   |    |  |
|--|-------------------|----|--|
| Technical data for design verification   |                   |    |  |
| Rated operational current for specified heat dissipation   | In                | Α  | 0  |
| Heat dissipation per pole, current-dependent   | P <sub>vid</sub>  | W  | 0  |
| Equipment heat dissipation, current-dependent  | P <sub>vid</sub>  | W  | 0  |
| Static heat dissipation, non-current-dependent   | $P_{vs}$          | W  | 0  |
| Heat dissipation capacity  | P <sub>diss</sub> | W  | 0  |
| Operating ambient temperature min.   |                   | °C | -25  |
| Operating ambient temperature max.   |                   | °C | 70   |
| IEC/EN 61439 design verification   |                   |    |  |
| 10.2 Strength of materials and parts   |                   |    |  |
| 10.2.2 Corrosion resistance  |                   |    | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures   |                   |    | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |                   |    | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects |                   |    | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |                   |    | Please enquire   |
| 10.2.5 Lifting   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.                                       |
| 10.2.6 Mechanical impact   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.                                       |
| 10.2.7 Inscriptions  |                   |    | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.                                       |
| 10.4 Clearances and creepage distances   |                   |    | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.                                       |
| 10.6 Incorporation of switching devices and components   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.                                       |
| 10.7 Internal electrical circuits and connections  |                   |    | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors   |                   |    | Is the panel builder's responsibility.   |
| 10.9 Insulation properties   |                   |    |  |
| 10.9.2 Power-frequency electric strength   |                   |    | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage   |                   |    | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material   |                   |    | Is the panel builder's responsibility.   |
| 10.10 Temperature rise   |                   |    | Not applicable.  |
| 10.11 Short-circuit rating   |                   |    | Is the panel builder's responsibility. The specifications for the switchgear must be observed.           |
| 10.12 Electromagnetic compatibility  |                   |    | Is the panel builder's responsibility. The specifications for the switchgear must be observed.           |
| 10.13 Mechanical function  |                   |    | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

# **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Front element for indicator light (EC000223)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Front element for warning lights (ecl@ss10.0.1-27-37-12-11 [AKF029014])

| [AKF029014])                                  | 377 | a and a annual control, it control and in grant (control and in 2 / control and in 2 / control and in a cont |
|---|-----|--|
| Suitable for number of built-in signal lights |     | 1  |
| Colour lens                                   |     | Green  |
| Construction type lens                        |     | Round  |
| Hole diameter                                 | mm  | 22.5   |
| Width opening                                 | mm  | 0  |
| Height opening                                | mm  | 0  |
| With front ring                               |     | No   |
| Material front ring                           |     | Plastic  |
| Colour front ring                             |     | Other  |
| Type of lens                                  |     | High   |

# **Approvals**

| ••                          |   |
|-----------------------------|---|
| Product Standards           | IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CE marking |
| UL File No.                 | E29184  |
| UL Category Control No.     | NKCR  |
| CSA File No.                | 012528  |
| CSA Class No.               | 3211-03   |
| North America Certification | UL listed, CSA certified                                |
| Degree of Protection        | UL/CSA Type 3R, 4X, 12, 13                              |

# **Dimensions**

